CCC - P67658 Page 1 of 1

PURAFIL ENVIRONMENTAL CORROSIVITY REPORT

19-Nov-2010

Company: 118610

Room/Area ID: Reference #:



 Sales Order #:
 C002688

 CCC Panel #:
 P67658

 Date In:
 19-Oct-2010

 Date Out:
 01-Nov-2010

Days In Service: 13

CCC Panel # P67658

ISA Class G2 Moderate

Copper Corrosion 492 Å/30 Days

Silver Corrosion 1804 Å/30 Days

(see next page for complete analysis)

Summary for PURAFIL CCC # P67658

The electrolytic reduction analysis on Corrosion Classification Coupon #P67658 shows the presence of moderate concentrations of contaminants in the environment tested. The hydrogen sulfide level is expected to range between 3 and 10 ppb and the sulfur dioxide level between 10 and 100 ppb. The effects of corrosion are measurable and may be a factor in determining equipment reliability.

Your local representative for additional information and assistance is:

Environmental Health and Eng

117 Fourth Avenue, Needham MA 02494, USA

tminegishi@eheinc.com

Purafil, Inc. / 2654 Weaver Way, Doraville GA 30340 USA / (770) 662-8545 / (770) 263-6922 Email: purafil@purafil.com / Internet: http://www.purafil.com

Displaying Page 1 Display Page 2


CCC - P67658 Page 1 of 1

PURAFIL CCC # P67658 Analysis Results

Corrosion Film Composition Projections				Gold Coupon - Magnified 20x
	30 Days	, <u>1 Year</u>	<u>5 Year</u>	magica zox
Copper Films				
Cu ₂ S	323 Å	647 Å	1106 Å	
Cu ₂ O	169 Å	338 Å	578 Å	
Unknowns	0 Å	0 Å	0 Å	
Totals	492 Å	985 Å	1684 Å	
Silver Films				
AgCl	0 Å	0 Å	0 Å	
Ag ₂ S	1804 Å	21970 Å	109848 Å	
Unknowns	0 Å	0 Å	0 Å	
Totals	1804 Å	21970 Å	109848 Å	
Gold Pore Corrosion: Note: 1000 Å = 0.1 micron				

Equipment Reliability Correlation

(ISA Standard S71.04-1985 for Copper)



Displaying Page 2 <u>Display Page 1</u>